

SECTION 22 LIVE FIRE TRAINING - 24 HOURS**BASIC - 4 Hours**

- 22-01.01 Trainee shall identify the current edition of NFPA 1403, Standard on Live Fire Training Evolutions and shall:
- A. identify the purpose of NFPA 1403
 - B. define evolution
 - C. define student
 - D. define instructor
 - E. define training center burn building
 - F. identify subjects required prior to participating in live fire training
 - G. identify the minimum flow, in gallons per minute, required by each hose line used in live fire training
 - H. identify the protective equipment required during live fire training

INTERMEDIATE - 20 Hours

- 22-02.01 Trainee, operating as the nozzle person and as a member of a team, shall control and/or extinguish the following live fires using appropriate protective equipment, fire fighting tools, and extinguishing agents:
- A. a one (1) room fire
 - B. a two (2) room fire
 - C. piles/stacks of class A combustible materials (exterior)
 - D. open pans of combustible materials (exterior)
 - E. vehicle fires
 - F. storage containers and
 - G. flammable gas cylinders (exterior)
- 22-02.02 Trainee, operating as a member of a team, shall perform vertical ventilation during live fire training.
- 22-02.03 Trainee, operating as a member of a team, shall perform horizontal ventilation during live fire training.
- 22-02.04 Trainee, operating as an individual or a member of a team, shall carry and raise ladders during live fire training.
- 22-02.05 Trainee shall extinguish a Class B fire with a portable fire extinguisher.

ADVANCED - 0 Hours

THESE LIVE FIRE TRAINING EVOLUTIONS SHOULD CONSIST OF A COMBINATION OF VARIOUS STAGES OF HOSE HANDLING, FIRE STREAMS, VENTILATION, ETC., NECESSARY IN THE ACTUAL EXTINGUISHMENT OF A FIRE. THE TRAINING CONDUCTED UNDER THIS SECTION MUST BE CARRIED OUT AS A PREPLANNED OPERATION WITH REFERENCE TO THE STANDARDS OF NFPA 1403 STANDARD ON LIVE FIRE TRAINING EVOLUTIONS. UNDER NO CIRCUMSTANCES SHALL RESPONSE TO ACTUAL ALARMS BE COUNTED AS TRAINING HOURS.